



- GENERAL NOTES:
- 1 PROVIDE LADDER-TYPE CABLE TRAY AT TELECOMMUNICATIONS ROOM. PROVIDE BASKET-TYPE CABLE TRAY OUTSIDE TELECOMMUNICATIONS ROOM.
 - 2 PROVIDE CABLE TRAY DROPOUTS FROM CABLE TRAY TO CABLE TRAY, AND CABLE TRAY TO TELECOMMUNICATIONS EQUIPMENT CABINET.
 - 3 PROVIDE #2 AWG BARE COPPER WIRE THROUGHOUT THE CABLE TRAY SYSTEM AND BOND TO EACH SECTION.
 - 4 PATHWAY SHOWN ARE DEDICATED FOR TELECOMMUNICATIONS, CCTV, AND AV ONLY.
 - 5 PROVIDE FIRESTOP MATERIAL IN AND AROUND SLEEVES AND CONDUITS THAT PENETRATE FIRE RATED WALLS OR FLOORS.
 - 6 SEISMICALLY BRACE PATHWAYS TO MEET THE PROJECTS SEISMIC RESTRAINT REQUIREMENTS.

- NOTES:
- 1 24" X 6" CABLE TRAY
 - 2 12" X 6" CABLE TRAY
 - 3 THROUGH-WALL FIRE RATED PATHWAY, SEE DETAIL T6.3

REVISION		
No.	Description	Date

TRMA
Taniguchi Ruth Makio Architects
100 Cliff Business Center, P.O. Box EA, Agaña, GU 96910
Tel.: (671) 475-8772 • Fax: (671) 472-3381

Architecture
Planning
Interior Design

eme
EMCE Consulting Engineers
SUITE 201, 133 ANTONIA COURT
P.O. BOX 9940 TAMUNING, GUAM 96931
671. 649-0166/7 Phone
671. 646-EMCE (3623) Fax

REGISTERED COMMUNICATIONS DISTRIBUTION DESIGNER
Bicsi
Abner V. Mariano
Reg No. 211020R
Expires 12/31/24
RCDD
Abner V. Mariano

ABNER V. MARIANO
REGISTERED PROFESSIONAL ENGINEER
373
COMMONWEALTH OF NORTHERN MARIANA ISLANDS
I HEREBY CERTIFY THAT THIS PLAN WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION
DATE: 10/07/2022

Project: NMC
PACKAGE 1: STUDENT CENTER BUILDING

Title: GROUND FLOOR TELECOMMUNICATIONS CABLE TRAY PLAN
CONSTRUCTION DOCUMENTS

Designed: JF/LB
Drawn: NP/RS
Checked: IA/AM
Supv: AM
Scale: AS INDICATED
Date: 10/07/2022
Project No. 24-22-493
Drawing No.

T3.1.2
Sheet No. of

1 GROUND FLOOR TELECOMMUNICATIONS CABLE TRAY PLAN
SCALE: 1/8" = 1'-0"

NORTH
0 4' 8' 16'
IF SHEET IS LESS THAN 24" X 36"
REDUCED PRINT - USE GRAPHIC SCALES