


1

EXTERIOR TELECOMMUNICATIONS CABINET ELEVATION

NOT TO SCALE



GENERAL NOTES:

- 1
- ALL EQUIPMENT CABINETS MUST BE ANCHORED TO FLOOR USING APPROVED MATERIALS AND METHODS.

- 2
- ALL PATCH CORDS MUST BE LABELED ON EACH END (APPROXIMATELY 3" FROM CONNECTOR)

- 3
- ALL PATCH PANELS MUST BE LABELED USING ANSI/TIA/EIA-606 LABELING SCHEME.

NOTES:

- 1
- PATCH PANEL FOR WAP OUTLET.

- 2
- PROVIDE RUGGEDIZED TYPE PATCH PANEL.

REVISIONS		
No.	Description	Date

TRMA

Taniguchi Ruth Makio Architects

100 Cliff Business Center, P.O. Box EA, Agaña, GU 96910

Tel.: (671) 475-8772 • Fax.: (671) 472-3381

Architecture
Planning
Interior Design

eme



EMCE • Consulting engineers

SUITE 201, 133 ANTONIA COURT

P.O. BOX 8888 TAMUNING, GUAM 96931

671 . 649-0166/7 Phone

671 . 646-EMCE (3623) Fax



Project:

NMC

PACKAGE 2: EXTERIOR IMPROVEMENTS - SITE WORK ADDITIVE BID ITEM #1

Title:

EXTERIOR TELECOMMUNICATIONS CABINET ELEVATION

CONSTRUCTION DOCUMENTS

Designed: JF/LB

Drawn: NP/RS

Checked: IA/AM

Supv: AM

Scale: AS INDICATED

Date: 10/07/2022

Project No.

Drawing No.

T2.11

Sheet No. _____ of _____