

NOTES:

- 1 SEE SHEET E9.10 FOR 2'X2' HANDHOLE.
- 2 MOUNT 10'-0" AFF.
- 3 SEE SHEET E9.8 FOR RECEPTACLE MOUNTING DETAIL.

ELECTRICAL DUCT SCHEDULE

DUCT DESIGNATION	CONDUIT SIZE
SP1	1"
SP2	2"
S1	1"
S2	1 1/2"
S3	2"

SEE PANEL SCHEDULES ON PACKAGE-1 FOR WIRING INFORMATION.

REVISIONS		
No.	Description	Date
1	ADDENDUM 1	12/6/22

TRMA
Taniguchi Ruth Makio Architects
100 Cliff Business Center, P.O. Box EA, Agaña, GU 96910
Tel.: (671) 475-6772 • Fax: (671) 472-3381

Architecture
Planning
Interior Design

emce
EMCE • Consulting engineers
SUITE 201, 133 ANTONIA COURT
P.O. BOX 8888 TAMUNING, GUAM 96931
671. 649-0166/7 Phone
671. 646-EMCE (3623) Fax

REGISTERED PROFESSIONAL ENGINEER
373
I HEREBY CERTIFY THAT THIS PLAN WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION
Abm V. Morris
DATE: 10/17/2022

Project:
NMC
PACKAGE 2: EXTERIOR IMPROVEMENTS - SITE WORK
ADDITIVE BID ITEM #1


Title:
ELECTRICAL SITE PLAN - SHEET 3

100% CONSTRUCTION DOCUMENTS

Designed: JF/LB
Drawn: NP/RS
Checked: IA/AM
Supv: AM
Scale: AS INDICATED
Date: 09/28/2022
Project No. 24-22-293
Drawing No.

ES1.3
Sheet No. of

1 ELECTRICAL SITE PLAN - SHEET 3
SCALE: 3/32"=1'-0"



IF SHEET IS LESS THAN 24" X 36"
REDUCED PRINT - USE GRAPHIC SCALES