


- GENERAL NOTES:**
- ALL EQUIPMENT CABINETS MUST BE ANCHORED TO FLOOR USING APPROVED MATERIALS AND METHODS.
 - CONTRACTOR MUST INSTALL, TERMINATE AND TEST ALL SIGNAL, POWER AND GROUND CABLES AS PER CONTRACT.
 - NEATLY BUNDLE (DRESS CABLES LONGITUDINALLY) AND SUPPORT (USING FASTENERS AND TIES) TELECOMMUNICATIONS CABLES ONTO CABLE TRAY. NEATLY BUNDLE AND SUPPORT TELECOMMUNICATIONS CABLES ONTO VERTICALLY MOUNTED CABLE RUNWAY WHEN RISING FROM FLOOR SLEEVES OR DESCENDING FROM CEILING SLEEVES USING APPROVED TIES. NEATLY BUNDLE TELECOMMUNICATIONS CABLE ONTO THE BACK OF THE VERTICAL CABLE MANAGEMENT SECTION USING APPROVED TIES. DRESS TELECOMMUNICATIONS CABLE FROM THE VERTICAL MANAGEMENT SECTIONS TO THE TERMINATION POSITION.
 - ALL PATCH CORDS MUST BE LABELED ON EACH END (APPROXIMATELY 3" FROM CONNECTOR)
 - ALL PATCH PANELS MUST BE LABELED USING ANSI/TIA/EIA-606 LABELING SCHEME.
 - PROVIDE RADIUS DROPOUTS WHERE CABLES TRANSITION DOWNWARD FROM OVERHEAD HORIZONTAL CABLE TRAY.
- NOTE:**
- TELECOMMUNICATIONS CABINET. FOR ADDITIONAL REQUIREMENTS. SEE SHEET

1
T6.5



I HEREBY CERTIFY THAT THIS PLAN WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION
DATE: 10/7/2022

Project: NMC
PACKAGE 1: STUDENT CENTER BUILDING

Title: TELECOMMUNICATIONS CABINET ELEVATIONS - SHEET 1
CONSTRUCTION DOCUMENTS

Designed: JF/LB
Drawn: NP/RS
Checked: IA/AM
Supv: AM
Scale: AS INDICATED
Date: 10/07/2022

Project No. File
Drawing No.

T2.1

Sheet No. of

IF SHEET IS LESS THAN 24" X 36"
REDUCED PRINT - USE GRAPHIC SCALES