



- GENERAL NOTES:
- 1 PROVIDE LADDER-TYPE CABLE TRAY AT TELECOMMUNICATIONS ROOM. PROVIDE BASKET-TYPE CABLE TRAY OUTSIDE TELECOMMUNICATIONS ROOM.
  - 2 PROVIDE CABLE TRAY DROPOUTS FROM CABLE TRAY TO CABLE TRAY, AND CABLE TRAY TO TELECOMMUNICATIONS EQUIPMENT CABINET.
  - 3 PROVIDE #2 AWG BARE COPPER WIRE THROUGHOUT THE CABLE TRAY SYSTEM AND BOND TO EACH SECTION.
  - 4 PATHWAY SHOWN ARE DEDICATED FOR TELECOMMUNICATIONS, CCTV, AND AV ONLY.
  - 5 PROVIDE FIRESTOP MATERIAL IN AND AROUND SLEEVES AND CONDUITS THAT PENETRATE FIRE RATED WALLS OR FLOORS.
  - 6 SEISMICALLY BRACE PATHWAYS TO MEET THE PROJECTS SEISMIC RESTRAINT REQUIREMENTS.

- NOTES:
- 1 24" X 6" CABLE TRAY
  - 2 12" X 6" CABLE TRAY
  - 3 THROUGH-WALL FIRE RATED PATHWAY, SEE DETAIL 5 T6.3.

1 SECOND FLOOR TELECOMMUNICATIONS CABLE TRAY PLAN  
SCALE: 1/8" = 1'-0"



IF SHEET IS LESS THAN 24" X 36"  
REDUCED PRINT - USE GRAPHIC SCALES

REVISION		
No.	Description	Date

**TRMA**  
Taniguchi Ruth Makio Architects  
1100 Cliff Business Center, P.O. Box EA, Agaña, GU 96910  
Tel.: (671) 475-8772 • Fax: (671) 472-3381

Architecture  
Planning  
Interior Design

**emce**  
EMCE Consulting Engineers  
SUITE 201, 133 ANTONIA COURT  
P.O. BOX 9940 TAMUNING, GUAM 96931  
671. 649-0166/7 Phone  
671. 646-EMCE (3623) Fax

**Bicsi**  
Abner V. Mariano  
Res No. 211020R  
Expires 12-31-24  
RCDD  
10/7/2022

ABNER V. MARIANO  
REGISTERED PROFESSIONAL ENGINEER  
373  
10/7/2022

Project:  
NMC  
PACKAGE 1: STUDENT  
CENTER BUILDING

Title:  
SECOND FLOOR  
TELECOMMUNICATIONS  
CABLE TRAY PLAN

CONSTRUCTION  
DOCUMENTS

Designed:	JF/LB
Drawn:	NP/RS
Checked:	IA/AM
Supv:	AM
Scale:	AS INDICATED
Date:	10/07/2022
Project No.	24-22-493
File	
Drawing No.	

T3.2.2  
Sheet No. of